

TÜV Rheinland Energie und Umwelt GmbH
51101 Köln

TRI-ROOF
TriEnergy GmbH | TRITEC Logistics
Boschstraße 2/4
71287 Weissach

Dominik Kolter
Tel. ++49-221/806-3956
Fax ++49-221/806-1350
Mail dominik.kolter@de.tuv.com
Web www.tuv.com/pv

25.11.2010

Declaration
- 21211216 -

Customer: TriEnergy GmbH | TRITEC Logistics
Boschstraße 2/4
71287 Weissach

Product: Mounting system, TRI-STAND
Module type: Solar World; SW 220 poly
Kyocera; KD 210 GH 2PU

Basis of testing: IEC 61215:2005 "Crystalline silicon terrestrial photo-
voltaic (PV) modules – Design qualification and type
approval"
Test 10.16 mechanical load test with 2400 Pa and
5400 Pa for heavy snow loads.

Test result:

The mechanical load test 10.16 of the EN IEC 61215:2005 standard were passed according to its regulations of the pass criteria. It is therefore declared, that the photovoltaic modules in combination to the mounting system of the aforementioned types fulfil the requirements for extended load (5400 Pa) of the standard EN IEC 61215:2005.

TriEnergy`s | TRITEC`s mounting system TRI-STAND is for integrated installation of PV-modules. The PV-modules will be fixed over the whole length of the short side of the aluminium frame, for higher load (5400 Pa), an additional support rail will be necessary. The dimension of the profiles is specific to the module dimensions.

Cologne, November 2010

Renewable Energies

i. V.


Dipl.-Ing. J. Althaus

i. A.


Dipl.-Ing. D. Kolter

TÜV Rheinland
Energie und Umwelt GmbH

Am Grauen Stein
51105 Köln

Tel. ++49-221/806-2477
Fax ++49-221/806-1350
Mail enertest@de.tuv.com
Web www.umwelt-tuv.de

Geschäftsführung
Dr.-Ing. Wolfgang Jockel

Amtsgericht Köln HRB 56171